

CITY OF SAUSALITO
420 Litho Street, Sausalito, CA 94965

Addendum No. 3

Issued **October 16, 2025**

BRIDGEWAY SLIDE REPAIR PROJECT MSE WALL ALTERNATIVE

Page 1 of 1

NOTICE TO ALL PLAN HOLDERS SUBMITTING BIDS FOR THIS WORK:

You are hereby notified of the following information, changes, clarifications or modifications to the original Contract Documents, Project Manual, Drawings, Specifications and subsequent Addenda. This Addendum shall supersede the original Contract Documents and previous Addenda wherein it contradicts the same and shall take precedence over anything to the contrary therein. All other conditions remain, UNCHANGED.

This Addendum is hereby made a part of the Contract Documents to the same extent as though it were originally included therein.

RESPONSE TO QUESTIONS

Q. We are curious to know if you would be interested in an alternative MSE system (Old Castle Anchor block system), instead of the Versa-Lok Standard? We would include a shop drawing package with calcs and stamped design.

A. Not an approved equivalent. The versa-lok have pinned connections that make a strong connection with the geogrid. The old castle is a gravity friction connection more susceptible to damage during seismic event.

END OF ADDENDUM NO. 3

Issued By: City of Sausalito
Andrew Davidson
Senior Engineer

ACKNOWLEDGED

Bidder's Signature

A signed copy of this addendum is to be submitted as a part of the bid package for the subject project. Failure to do so may subject the Bidder to Disqualification.